



Town of Bluffton

Invitation for Bids (IFB 2015-50)

BUCKISLAND - SIMMONSVILLE SEWER EXTENSION (PHASE THREE)

CDBG GRANT NUMBER 4-V-12-007

Questions & Answers

07/24/15

1. I have a set of plans for this job but they are dated May 2012, is this the latest set?

- **Response** - May 2012 with a latest revised set signed 8/23/2012 is the latest set of plans.

2. The bid form calls for some 10" PVC, but none are on the plans, is this correct?

- **Response** - All pipe is 8", a revised Bid Proposal will be supplied. See Addendum #1

3. The bid form call for 20" casing while the plans call for 16", which is correct?

- **Response** - 16" Casing is correct, a revised Bid proposal will be provided. See Addendum #1

4. The alternate on the bid form calls for a lot more material than the alternate on the plans, which is correct?

- **Response** - Both are correct the alternate is for actual house connections. The base bid is for the infrastructure within the Rights of Way and easements.

5. Should we include a schedule?

- **Response** – Yes, please see Addendum #1, Item 2.